

Approval Number 250355013
Test Report: 24-51076, 24-51077 & 24-51078



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

18th February 2025

IT-Keramik Srl.
Via Manzoni 35,
22030 Orsenigo,
Italy

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

CERAMIC

5023

'ITK-STE 221 (cream coloured), ITK-AL 99 (cream coloured) & ITK-AL96 (white coloured)'. Compression moulded and sintered ceramic sealing rings. For use with water up to 85°C.

APPROVAL NUMBER: 250355013
APPROVAL HOLDER: IT-KERAMIK SRL.

This is a re-approval of 2002529 which is valid between February 2020 and February 2025.

The Scheme reserves the right to review approval.
Approval 250355013 is valid between March 2025 and March 2030

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a horizontal line extending to the right.

Ian Hughes
WRAS Approvals Manager